CERTIFICATE OF COMPLIANCE

Certificate Number 20161108-E228634

Report Reference E228634-20151219

Issue Date 2016-October-08

Issued to: DOUGLAS ELECTRICAL COMPONENTS INC

5 Middlebury Blvd

Randolph NJ 07869-1112

This is to certify that representative samples of

CONDUIT FITTINGS FOR USE IN HAZARDOUS

LOCATIONS

See addendum page

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard No. UL 1203, 5th Ed., Rev. 2015-10-16,

Explosion-Proof and Dust-Ignition-Proof Electrical

Equipment for Use in Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC





CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date 20161108-E228634 E228634-20151219 2016-October-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

MODELS

Hubs, Cat. Nos. 52240 and 52540, trade size 1/2, 3/4, and 1 in., for use in Class I, Division 1, Groups A, B, C and D Hazardous Locations

Hubs, Cat. Nos. 52539, trade size 1/2 and 3/4 in., for use in Class I, Division 1, Groups B, C and D Hazardous Locations

Hubs, Cat. Nos. 52240 and 52539, trade size 1/2 and 1 in., for use in Class I, Division 1, Groups C and D Hazardous Locations.

Bamaly

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, pleas contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

